

PART III

CALCULATIONS

# 2026 CT CEU's for Electricians

APPENDIX "B" Calculations Based on  
the 2023 NEC

Time to open your code books!!!

## Floor area calculation 220.5(C) Question

Calculate the floor area to determine the proper square footage to be used for the load calculations.

Structure size is Length: 40 feet 6 inches= 40.5 feet Width: 50 feet 6 inches= 50.5 feet or 2091sq feet

Garage is 18.6 by 16.6 or 323 sq feet

Open porch Length: 24 feet 0 inches= 24.0 feet.

Width: 19 feet 0 inches= 19.0 feet

- A. 2,045.25 square feet
- B. 1,275 square feet
- C. 1,729.85 square feet
- D. 1,589.25 square feet

**Solution:**

Section 220.5(C) Length: 40 feet 6 inches= 40.5 feet Width: 50 feet 6 inches= 50.5 feet  $40.5 \text{ ft} \times 50.5 \text{ ft} = 2,045.25 \text{ square feet}$

Not Included is the Open Porch Length: 24 feet 0 inches= 24.0 feet Width: 19 feet 0 inches= 19.0 feet  $24 \text{ ft} \times 19 \text{ ft} = 456.0 \text{ square feet}$

Calculated floor area Total outside dimension - not included  $2,045.25 \text{ ft}^2 - 456.0 \text{ ft}^2$   
1,589.25 square feet

Answer D. 1,589.25 square feet

- Load calculation for Electric Vehicle Supply Equipment 220.57

### Question 1

A multi-unit dwelling complex has 4 electric vehicle charging stations, each rated at 6.8 kW (240V, single-phase) from the nameplate.

What is the minimum calculated load (in kilowatts) that must be considered for the feeder calculation serving the EV charging stations?

- A. 27.2 kW
- B. 34.0 kW
- C. 36.1 kW
- D. 28.8 Kw

**Solution:**

Section 220.57

The EVSE load shall be calculated at either 7200 watts (volt-amperes) or the nameplate rating of the equipment, whichever is higher.

$$7.2 \text{ kW} \times 4 = 28.8 \text{ kW}$$

**Answer:**

D. 28.8 kW

**Question 2**

What is the minimum branch circuit size for a Level II EVSE with a 32-ampere current rating?

- A. 32 A
- B. 35 A
- C. 40 A
- D. 55 A

**Solution:**

Sections 625.42 and 210.19(A)(1) EVSE are considered a continuous load so the branch circuit must be rated at 125% of the continuous load.

$$32 \text{ A} \times 1.25 = 40 \text{ A} \text{ minimum OCPD}$$

**Answer: C. 40 A****Question 3**

What is the minimum size XHHW-2 copper conductor permitted to supply a Level II EVSE that has a 30-ampere current rating, assuming 75° terminations?

- A. 12 AWG
- B. 10 AWG
- C. 8 AWG
- D. 6 AWG

Sections 625.42 and 210.19(A)(1) EVSE are considered a continuous load so the branch circuit must be rated at 125% of the continuous load.

$$30 \text{ A} \times 1.25 = 37.5 \text{ A}$$

Table 310.16

While XHHW-2 has a temperature rating of 90° C the conductor must be rated at 75° because of the terminations.

XHHW-2 = 8 AWG is rated for 50 A at 75° C.

**Answer: C. 8 AWG**

- **Problems using a temperature correction factor to cables, conductors in raceways**

## **Question 1**

What is the ampacity of a 4 THHN conductor terminated to an 80-ampere circuit breaker that is marked for 60°C/75°C terminations?

- A. 70 A
- B. 85 A
- C. 80 A
- D. 95 A

**Solution:**

Table 310.16

THHN Conductors have a 90°C rating

Section 110.14(C)(1)(a)(3)

The circuit breaker terminations are marked 60°C/75°C so you use the 75°C column of Table 310.16 to determine the ampacity of the 4 THHN conductors.

**Answer: B. 85 A**

**Question 2**

What is the ampacity of the 4 THHN conductors when terminated to the 80-ampere

circuit breaker when only marked for 60°C terminations?

A. 70 A

B. 85 A

C. 80 A

D. 95 A

**Solution:**

Table 310.16

THHN Conductors have a 90°C rating

Section 110.14(C)(1)(a)(1)

The circuit breaker terminations are marked 60°C so you use the 60°C column of Table 310.16 to determine the ampacity of the 4 THHN conductors.

**Answer: A. 70 A**

**Question 3**

Determine the ampacity of three 8 AWG THWN copper conductors installed in EMT in an ambient temperature of 40°C. All the conductors are current-carrying conductors. Calculate to the nearest ampere.

- A. 35 A
- B. 40 A
- C. 44 A
- D. 50 A

**Solution:**

Note 1:

Table 310.15(B) shall be referenced for ampacity correction factors where the ambient temperature is other than 30°C (86°F).

Table 310.16

8 AWG THWN = 50 A

Ambient Temperature Correction Based on 30°C (86°F)

Table 310.15(B)(1)(1), 75°C col.

THWN copper at 40°C = 0.88

$50 \text{ A} \times 0.88 = 44 \text{ A}$

**Answer: C. 44 A**

**Question 4**

A 3-conductor 8 AWG copper plus an equipment grounding conductor Type MC cable is installed in an area with an ambient temperature of 96°F. The conductors within the cable assembly have THHN insulation, and all three conductors are considered current-carrying conductors. Determine the ampacity of the current-carrying conductors in this application. Calculate to the nearest ampere.

- A. 35 A
- B. 40 A
- C. 45 A
- D. 50 A

**Solution:**

Table 310.16

8 AWG THHN = 55 A

Table 310.15(B)(1)(1), 90°C col.

THHN copper at 96°F = 0.91

$55 \text{ A} \times 0.91 = 50.05 \text{ A}$

**Answer: 50 A**

- Temperature Limitations of Equipment

**Question 1**

A 6 AWG THWN copper conductor is connected to a circuit breaker with termination temperature limitation marked (not to exceed) 60°C. What is the ampacity of the 6 AWG THWN copper conductor now that it is connected to this circuit breaker?

- A. 50 A
- B. 55 A
- C. 65 A
- D. 75 A

## Solution:

Table 310.14(1)

Table 310.16

6 AWG THWN = 65 A

Section 110.14(C)(1)(a)(2) Limited by circuit breaker to 60°C

110.14(C)(1)(a)(2) applies

Circuit breaker terminations = 60°C

Table 310.16 Ampacity

THWN ampacity at 75°C is not permitted

Use ampacity of 6 AWG copper at 60°C

6 AWG THWN copper limited to 60°C ampacity = 55 A

## Answer: 55 A

Eight 6 AWG THWN copper current-carrying conductors are installed to replace existing wiring within an existing single rigid metal conduit. The area of installation has an ambient temperature of 30°C. The new eight 6 AWG THWN conductors are connected to existing 50-ampere 2-pole circuit breakers with a marked terminal temperature rating of 60°C. What is the ampacity of the conductors, and is this an acceptable installation?

A. 45.5 A

B. 52.5 A

C. 55 A

D. 75 A

## **Solution:**

Section 110.14(C)(1)

Table 310.14(1)

Table 310.16 Ampacity

6 AWG THWN at 75°C = 65 A

Table 310.15(C)(1) Adjustment Factors

8 current-carrying conductors = 70%

$65 \text{ A} \times 0.70 = 45.5 \text{ A}$

6 AWG in 60°C column = 55 A

Ampacity = 45.5 A does not exceed the 60°C value but it is not large enough for the 50 A OCP so it is not permitted.

## **Answer: 45.5 A**

Eight 6 AWG THWN copper current-carrying conductors are installed to replace existing wiring within an existing single rigid metal conduit. The area of installation has an ambient temperature of 30°C. The new eight 6 AWG THWN conductors are connected to existing 50-ampere 2-pole circuit breakers with a marked terminal temperature rating of 60°C. What is the ampacity of the conductors, and is this an acceptable installation?

A. 45.5 A

B. 52.5 A

C. 55 A

D. 75 A

**Solution:**

Section 110.14(C)(1)

Table 310.14(1)

Table 310.16 Ampacity

6 AWG THWN at 75°C = 65 A

Table 310.15(C)(1) Adjustment Factors

8 current-carrying conductors = 70%

$$65 \text{ A} \times 0.70 = 45.5 \text{ A}$$

6 AWG in 60°C column = 55 A

Ampacity = 45.5 A does not exceed the 60°C value but it is not large enough for the 50 A OCP so it is not permitted.

**Answer: 45.5 A****Question 3**

Eight 6 AWG THHN copper current-carrying conductors are installed to replace existing wiring within an existing single rigid metal conduit. The area of installation has an ambient temperature of 30°C. The new eight 6 AWG THHN conductors are connected to existing 50-ampere 2-pole circuit breakers with a marked terminal temperature rating of 60°C. What is the ampacity of the conductors, and is this an acceptable installation?

E. 45.5 A

F. 52.5 A

G. 55 A

H. 75 A

## **Solution:**

Section 110.14(C)(1)

Table 310.14(1)

Table 310.16 Ampacity

6 AWG THHN at 90°C = 75 A

Table 310.15(C)(1) Adjustment Factors

8 current-carrying conductors = 70%

$75 \text{ A} \times 0.70 = 52.5 \text{ A}$

6 AWG in 60°C column = 55 A

Ampacity = 52.5 A does not exceed the 60°C value so it is permitted.

**Answer: 52.5 A**

## **• Continuous loads and branch circuit 210.20**

### **Question 1**

What is the minimum standard branch circuit size required for a 208-volt, single-phase, 8-kW continuous load, assuming terminations are rated for 75°C?

- A. 40 A
- B. 45 A
- C. 50 A
- D. 60 A

**Solution:**

Section 210.20(A)

Load = 8,000

208

Load = 38.46 A

Continuous load adjustment = Load x 125%

CL =  $38.46 \times 1.25$

CL = 48.08 A

Table 240.6(A)

Next standard breaker size = 50A

**Answer: C. 50 A is the next standard breaker size**

## Question 2

A 277-volt, single-phase circuit supplies a 6-kW continuous load and an 8 kW noncontinuous load.

1. What is the minimum standard size inverse-time circuit breaker (with terminations dual rated and marked at 60°C/75°C)?
  - A. 45 A
  - B. 50 A
  - C. 60 A
  - D. 70 A
2. Determine the minimum size XHHW-2 copper circuit conductors for this branch circuit.
  - A. 6 AWG
  - B. 4 AWG
  - C. 2 AWG
  - D. 1 AWG

## **Solution Part 1 OCPD Size:**

### **Calculation 1**

Continuous Load (CL)

CL = 6,000

277

CL = 21.7 A

### **Calculation 2**

Noncontinuous Load (NCL)

NCL = 8,000

277

NCL = 28.9 A

### **Calculation 3**

Section 210.20(A)

Minimum standard size inverse-time circuit breaker

Min. OCPD = (CL x 125%) + NCL

Min. OCPD = (21.7 x 125) + 28.9

Min. OCPD = 56 A

Table 240.6(A)

Next standard size rating is 60 A

**Answer: C. 60 A circuit breaker rated 60°C/75°C**

## **Solution Part 2 Conductor Size:**

210.19(A)

$$\text{Min. Ampacity} = (\text{CL} \times 125\%) + \text{NCL}$$

$$\text{Min. Ampacity} = (21.7 \times 125) + 28.9$$

$$\text{Min. Ampacity} = 56 \text{ A}$$

Section 110.14(C)(1)(a)(3)

90°C rated conductors connected to a circuit breaker rated 60°C/75°C

Table 310.16 Ampacity using 75°C

6 AWG XHHW-2 at 75°C is good for 65 A and can be protected by the 60A OCPD

**Answer: A. 6 AWG XHHW-2**

## • Continuous loads and feeders 215.3

### Question 1

A 3-phase, 4-wire feeder supplies a continuous load of 75 amperes and a noncontinuous load of 75 amperes to a second-floor equipment distribution switchboard.

Determining the minimum ampacity for this feeder, select the proper AWG XHHW-2 copper conductor size. The terminals of the circuit breaker and switchboard are rated 75°C.

- A. 1/0 AWG
- B. 2/0 AWG
- C. 3/0 AWG
- D. 4/0 AWG

## **Solution:**

215.2(A)(1) Minimum Rating and Size

$$\text{Min. Ampacity} = (\text{CL} \times 125\%) + \text{NCL}$$

$$\text{Min. Ampacity} = (75 \times 125) + 75$$

$$\text{Min. Ampacity} = 168.75 \text{ A}$$

Section 110.14(C)(1)(a)(3)

XHHW-2 Conductors are rated for 90°C but the terminals are rated for 75°C.

Table 310.16 Ampacity using 75°C

2/0 AWG XHHW-2 at 75°C is good for 175A

**Answer: B. 2/0 AWG XHHW-2**

## **Question 2**

A feeder supplies a continuous load of 100 amperes and a noncontinuous load of 35 amperes.

1. What is the minimum standard rating of time-delay fuses used for the feeder overcurrent protection?

- A. 150 A
- B. 175 A
- C. 200 A
- D. 225 A

2. What size THWN copper conductors are needed?

- A. 1 AWG
- B. 1/0 AWG
- C. 2/0 AWG
- D. 3/0 AWG

## **Solution:**

### **Calculation 1**

Section 215.3 OCPD selection

$$\text{Min. OCPD} = (\text{CL} \times 125\%) + \text{NCL}$$

$$\text{Min. OCPD} = (100 \times 125\%) + 35$$

$$\text{Min. OCPD} = 160 \text{ A}$$

Table 240.6(A)

Next standard size rating is 175 A

**Answer: B. 175 A time-delay fuse**

### **Calculation 2**

Section 215.2(A)(1) Minimum Rating and Size

Table 310.16

2/0 AWG THWN has an ampacity of 175 A and has adequate ampacity for 160 A load

**Answer: C. 2/0 AWG THWN**

- **Table 300.5(A) Minimum Cover Requirements**

### **Question 1**

A homeowner would like to add a 120/240-volt four circuit panel for lights and receptacles to a shed located 75 feet from the house. They have an extra bundle of EMT and wire from a previous project and want to use that instead of buying new conduit. What is the minimum burial depth for the EMT?

- A. EMT is not permitted for direct burial
- B. 12 inches
- C. 18 inches
- D. 24 inches

### **Solution:**

Table 300.5(A)

Column 3 for One-and two-family dwellings

Answer is C. 18 inches

## **Question 2**

You are installing a 24-volt lighting circuit for an outdoor decorative fountain in a landscaped public area. The power source is a listed Class 2 power supply, and the lighting circuit is limited to not more than 30 volts. The circuit is run underground using Type UF cable with GFCI protection and overcurrent protection not exceeding 20 amperes.

- A. 6 inches
- B. 12 inches
- C. 18 inches
- D. 24 inches

## **Solution:**

Table 300.5(A)

Table 300.5(A), Note 2, low-voltage circuits ( $\leq 30V$ ) with GFCI and  $\leq 20A$  protection may be buried at 6 inches using direct burial cable such as UF.

**Answer: A. 6 inches**

- Adding conductors to an existing box 314

**Question 1**

What is the maximum number of 14 AWG conductors that can be added and pulled through the  $4 \times 1 \frac{1}{2}$  square box?

- A. 4
- B. 6
- C. 8
- D. 10

**Solution:**

Table 314.16(A)

Volume of a  $4 \times 1 \frac{1}{2}$  square box = 21 in.3

Table 314.16(B)(1)

Existing 12 AWG = 2.25 in.3

Total occupied space is 4 conductors:  $4 \times 2.25$  cubic inches = 9

Unoccupied space:  $21 - 9 = 12$  in.3

Table 314.16(B)(1)

14 AWG = 2 in.3 with 12 cubic inches remaining

Number of conductors =  $12 / 2$

**Answer: B. 6 additional 14 AWG conductors**

**Question 1**

Determine the maximum number of additional 12 AWG conductors that can be added and added and spliced in a 12 in.  $\times$  12 in.  $\times$  4 in. junction box when it already contains 12 spliced 12 AWG conductors.

- A. 244 additional conductors
- B. 256 additional conductors
- C. 286 additional conductors
- D. 290 additional conductors

**Solution:**

Step 1: Determine the Junction Box Volume

12 in.  $\times$  12 in.  $\times$  4 in.

Volume = 576 cubic inches

Step 2: Volume Allowance per Conductor

Table 314.16(B)

12 AWG = 2.25 cubic inches

Step 3: Volume Used by Existing Conductors

12 – 12 AWG Spliced conductors  $\times$  2.25 cubic inches = 27 cubic inches

Step 4: Remaining Box Volume

576 cu in – 27 cu in = 549 cubic inches remaining

Step 5: Determine How Many Additional Spliced Conductors Can be Added

Each spliced conductor = 1 box fill unit = 2.25 cu in

549 / 2.25

= 244 additional conductors

**Answer: A. 244 additional conductors**

- Maximum number of conductors spliced in a conduit body 314.16(C)

**Question 1**

Determine the maximum number of 6 AWG THW conductors that can be spliced in a 2-inch EMT conduit body that is marked with a volume allowance of 82 cubic inches.?

- A. 8
- B. 10
- C. 14
- D. 16

## **Solution:**

Section 314.16(C)

Table 314.16(B)(1)

Step 1: Volume Allowance Required per Conductor

6 AWG = 5 in.<sup>3</sup>

Step 2: Calculate the Maximum Number of Spliced 6 AWG Conductors

$82 / 16.4$

= 5

**Answer: 16 Conductors**

## **Question 2**

A Type T conduit body is used as a junction box installation. It has a volume marked as 20.0 cubic inches. What is the maximum number of 12 AWG THHN conductors that may be spliced inside this conduit body.

- A. 6
- B. 8
- C. 9
- D. 10

## **Solution:**

Section 314.16(C)

Table 314.16(B)(1)

Step 1: Volume Allowance Required per Conductor

12 AWG = 2.25 in.<sup>3</sup>

Step 2: Calculate the Maximum Number of Spliced 12 AWG Conductors

20/8.8

= 2.25

**Answer: B. 8 Conductors**

- Voltage drop examples

**Question 1**

Calculate the voltage drop on a single-phase circuit with 32 amperes of load, 320 feet from the load to the panelboard, and served by 8 AWG copper THHN conductors.

- A. 13 V
- B. 14 V
- C. 15 V
- D. 16 V

## Solution:

Where:

$K = 12.9$  for copper or  $21.2$  for aluminum

$I = 32 \text{ A}$

$D = 320 \text{ ft}$

$CM = \text{Circular mils of the conductor}$

Chapter 9, Table 8

$$V_d = 2 \times K \times I \times D / CM$$

$$V_d = 2 \times 12.9 \times 32 \times 320 / 16,510$$

8 AWG copper = 16,510 CM

$$V_d = 2 \times K \times I \times D / CM$$

$$V_d = 2 \times 12.9 \times 32 \times 320 / 16,510$$

$$V_d = 263,424 / 16510$$

$$V_d = 15.95 \text{ V}$$

**Answer: D. 16 V**

## Question 2

A 480-volt branch circuit is to be installed with three 1/0 AWG THWN copper conductors serving a 140-ampere, 3-phase load. Determine the maximum length of the conductors, with the voltage drop not exceeding 3%

- .
  - A. 460 feet
  - B. 477 feet
  - C. 493 feet
  - D. 502 feet

## **Solution:**

210.19 Informational Note

$$V_d = V_{Supply} \times 3\%$$

$$V_d = 480 \times 0.03$$

$$V_d = 14.4 \text{ V}$$

Chapter 9 Table 8

1/0 AWG = 105,600 cmil

$$L = CM \times V_d / 1.73 \times K \times I$$

$$L = 105,600 \times 14.4 / 1.73 \times 2.9 \times 140$$

$$L = 477 \text{ feet}$$

**Answer: B. 477 feet**

**AND NOW IT IS TIME FOR CHAPTERS  
1- 3 OF YOUR 2023 CODE CHANGES**